

NONPAREIL PROCESSING CORPORATION (PWS 6060051) SOURCE WATER ASSESSMENT FINAL REPORT

November 21, 2002



State of Idaho Department of Environmental Quality

Disclaimer: This publication has been developed as part of an informational service for the source water assessments of public water systems in Idaho and is based on the data available at the time and the professional judgement of the staff. Although reasonable efforts have been made to present accurate information, no guarantees, including expressed or implied warranties of any kind, are made with respect to this publication by the State of Idaho or any of its agencies, employees, or agents, who also assume no legal responsibility for the accuracy of presentations, comments, or other information in this publication. The assessment is subject to modification if new data is produced.

Executive Summary

Under the Safe Drinking Water Act Amendments of 1996, all states are required by the U.S. Environmental Protection Agency (EPA) to assess every source of public drinking water for its relative sensitivity to contaminants regulated by the act. This assessment is based on a land use inventory of the designated assessment area, sensitivity factors associated with the well and aquifer characteristics.

This report, *Source Water Assessment for the Nonpareil Processing Corporation, Blackfoot, Idaho* describes the public water system (PWS), the boundaries of the zones of water contribution, and the associated potential contaminant sources located within these boundaries. This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. **The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the water system.**

The Nonpareil Processing Corporation (PWS # 6060051) is classified as a non-community, non-transient water system located in Bingham County (Figure 1). The drinking water system has one well source that serves approximately 75 persons through 1 metered connection. The well is housed in a wellhouse and located adjacent to an office building.

The potential contaminant sources within the delineation capture zones include underground storage tank (UST) sites, leaking underground storage tank (LUST) sites, sand and gravel pits, wastewater land application (WLAP) sites, and dairies. Also found were sites regulated under the Superfund Amendments and Reauthorization Act (SARA), the Resource Conservation Recovery Act (RCRA), and the Toxic Release Inventory (TRI). Other sources identified that may contribute to the overall vulnerability of the water source were businesses within the delineated areas that may be considered potential contaminant sources, the extensive irrigation canal systems, and deep injection wells. Injection wells regulated under the Idaho Department of Water Resources generally are for the disposal of stormwater runoff or agricultural field drainage. There are also recharge points (active, proposed, and possible recharge sites on the Snake River Plain) located within the well's delineation. Additionally, Highway 20, Highway 26, Interstate 15, and a railroad are transportation corridors that cross the delineation. If an accidental spill occurred from any of these corridors, inorganic chemical (IOC; i.e., nitrates, arsenic) contaminants, volatile organic chemical (VOC; i.e., petroleum products) contaminants, synthetic organic chemical (SOC; i.e., pesticides) contaminants, or microbial (i.e., bacteria) contaminants could be added to the aquifer system. A complete list of potential contaminant sources is provided with this assessment (Appendix A).

For the assessment, a review of laboratory tests was conducted using the State Drinking Water Information System (SDWIS). Total coliform bacteria have not been detected in the distribution system. The IOCs fluoride and nitrate have been detected in the drinking water, but at levels below the maximum contaminant levels (MCL) for each chemical. The VOC, tetrachloroethylene (PCE) was detected in March 1999 and June 1999 with concentrations ranging from 0.00072 milligrams per Liter (mg/L) to 0.00087 mg/L. The MCL for PCE is 0.005 mg/L. In September 1993, the VOC, trichloroethane was detected in the well water at a concentration of 0.0034 mg/L. The MCL for trichloroethane is 0.005 mg/L. No SOCs have been detected in the drinking water.

The capture zones for the well intersect a priority area for the SOC atrazine. The organic priority area is areas where greater than 25% of the wells show levels greater than 1% of the primary standard or other health standards (MCL for atrazine is 0.003 mg/L). Atrazine is a widely used herbicide for control of broadleaf and grassy weeds.

The susceptibility ratings for the Nonpareil Processing Corporation drinking water system were based upon available information relating to soil drainage characteristics, agricultural land use, system construction, and potential contaminant sources identified within the well's zones of contribution.

The final susceptibility rankings for the well automatically scored high for VOCs because PCE and trichloroethane were detected in the well water. The well also rated high for IOCs, SOC, and microbial contaminants.

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a "pristine" area or an area with numerous industrial and/or agricultural land uses that require surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources. If the system should need to expand in the future, new well sites should be located in areas with as few potential sources of contamination as possible, and the site should be reserved and protected for this specific use.

An effective drinking water protection program is tailored to the particular local drinking water protection area. A community with a fully developed drinking water protection program will incorporate many strategies. For the Nonpareil Processing Corporation, drinking water protection activities should focus on identifying the sources of VOCs in the drinking water. The system should also continue its efforts aimed at keeping the distribution system free of microbial contaminants that may affect the drinking water quality. If PCE or other chemicals tested (i.e. trichloroethane) approach or exceed the MCL, the system should take appropriate measures to treat the water source. Treatments, such as granular activated charcoal and packed tower aeration for VOCs could be investigated to remedy these problems.

In addition, drinking water protection activities should focus on correcting any deficiencies outlined in the sanitary survey (an inspection conducted every five years with the purpose of determining the physical condition of a water system's components and its capacity). Installing a well vent would be a good first step to system improvement. The well should maintain sanitary standards regarding wellhead protection. Also, any new sources that could be considered potential contaminant sources in the well's zones of contribution should also be investigated and monitored to prevent future contamination. No potential contaminants (pesticides, paint, fuel, cleaning supplies, etc.) should be stored or applied within 50 feet of the well.

Land uses within most of the source water assessment area are outside the property boundary for Nonpareil Processing Corporation. Therefore, partnerships with state and local agencies, and industrial and commercial groups should be established to ensure future land uses are protective of ground water quality. Educating employees and the public about source water will further assist the system in its monitoring and protection efforts.

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. A strong public education program should be a primary focus of any drinking water protection plan. Public education topics could include hazardous waste disposal methods and the importance of water conservation to name but a few. There are multiple resources available to help water systems implement protection programs, including the Drinking Water Academy of the EPA. Drinking water protection activities for agriculture should be coordinated with the Idaho State Department of Agriculture and the Bingham County Soil and Water Conservation District. As major transportation corridors intersect the delineation (such as Highway 26 and Interstate 15), the Idaho Department of Transportation should be involved in protection efforts.

A system must incorporate a variety of strategies in order to develop a comprehensive drinking water protection plan, be they regulatory in nature (e.g. zoning, permitting) or non-regulatory in nature (e.g. good housekeeping, public education, specific best management practices). For assistance in developing protection strategies please contact the Pocatello Regional Office of the Idaho Department of Environmental Quality or the Idaho Rural Water Association.

SOURCE WATER ASSESSMENT FOR NONPAREIL PROCESSING CORPORATION, BLACKFOOT, IDAHO

Section 1. Introduction - Basis for Assessment

The following sections contain information necessary to understand how and why this assessment was conducted. **It is important to review this information to understand what the ranking of this source means.** A map showing the delineated source water assessment area and the inventory of significant potential sources of contamination identified within that area are contained in this report. The list of significant potential contaminant source categories and their rankings used to develop this assessment is also attached.

Level of Accuracy and Purpose of the Assessment

The Idaho Department of Environmental Quality (DEQ) is required by the U.S. Environmental Protection Agency (EPA) to assess over 2,900 public drinking water sources in Idaho for their relative susceptibility to contaminants regulated by the Safe Drinking Water Act. This assessment is based on a land use inventory of the delineated assessment area, sensitivity factors associated with the well, and aquifer characteristics. All assessments must be completed by May of 2003. The resources and time available to accomplish assessments are limited. Therefore, an in-depth, site-specific investigation to identify each significant potential source of contamination for every public water supply system is not possible. **This assessment should be used as a planning tool, taken into account with local knowledge and concerns, to develop and implement appropriate protection measures for this source. The results should not be used as an absolute measure of risk and they should not be used to undermine public confidence in the public water system (PWS).**

The ultimate goal of the assessment is to provide data to local communities to develop a protection strategy for their drinking water supply system. DEQ recognizes that pollution prevention activities generally require less time and money to implement than treatment of a public water supply system once it has been contaminated. DEQ encourages communities to balance resource protection with economic growth and development. The decision as to the amount and types of information necessary to develop a drinking water protection program should be determined by the local community based on its own needs and limitations. Wellhead or drinking water protection is one facet of a comprehensive growth plan, and it can complement ongoing local planning efforts.

Section 2. Conducting the Assessment

General Description of the Source Water Quality

The Nonpareil Processing Corporation (PWS # 6060051) is classified as a non-community, non-transient water system located in Bingham County (Figure 1). The drinking water system has one well source that serves approximately 75 persons through 1 metered connection. The well is located adjacent to an office building and driving area.

Total coliform bacteria have not been detected in the distribution system. The inorganic chemicals (IOCs) fluoride and nitrate have been detected in the drinking water, but at levels below the maximum contaminant levels (MCL) for each chemical. The volatile organic chemical (VOC) tetrachloroethylene (PCE) was detected in March 1999 and June 1999 with concentrations ranging from 0.00072 milligrams per Liter (mg/L) to 0.00087 mg/L. The MCL for PCE is 0.005 mg/L. In September 1993, the VOC, trichloroethane was detected in the well water at a concentration of 0.0034 mg/L. The MCL for trichloroethane is 0.005 mg/L. No synthetic organic chemicals (SOCs) have been detected in the drinking water.

Defining the Zones of Contribution--Delineation

The delineation process establishes the physical area around the well that will become the focal point of the assessment. The process includes mapping the boundaries of the zone of contribution into time-of-travel (TOT) zones (zones indicating the number of years necessary for a particle of water to reach a pumping well) for water in the aquifer. Washington Group International (WGI) was contracted by DEQ to define the public water system's zones of contribution. WGI used a refined computer model approved by the EPA in determining the 3-year (Zone 1B), 6-year (Zone II), and 10-year (Zone III) TOT for water associated with the East Margin Area of the Eastern Snake River Plain (ESRP) hydrologic province in the vicinity of the Nonpareil Processing Corporation. The computer model used site-specific data, assimilated by WGI from a variety of sources including well logs (when available), operator records, and hydrogeologic reports. A summary of the hydrogeologic information from the WGI report is provided below.


Hydrogeologic Conceptual Model

The East Margin Area encompasses 821 square miles, representing approximately 8 percent of the total area of the ESRP hydrologic province. The majority of the East Margin Area is within Bingham County, with small areas occurring in Bannock, Bonneville, and Power counties.

The regional ESRP aquifer is the most significant aquifer in the East Margin Area and consists primarily of basalt of the Quaternary-aged Snake River Group. However, additional water-bearing units are used for water supply along the margin of the ESRP. In order of decreasing age, the most significant aquifers in the Michaud Flats area are bedded rhyolite (volcanic rock) of the Tertiary-aged Starlight Formation and Quaternary-aged gravels of a low relief plain formed by running water (pediment), basalt of the Big Hole Formation, and stream deposits of the Sunbeam Formation (see Jacobson, 1982, p. 7, and Corbett, et al., 1980, pp. 6-10). A few shallow domestic wells in the central Michaud Flats area also are completed in Michaud Gravel, which is the shallow water-table aquifer. The American Falls Lake Beds Formation (AFLB) confines the deeper aquifers and averages 80 feet in thickness in the central Michaud Flats area (Jacobson, 1984, p. 6). The AFLB pinches out in the eastern Michaud Flats area near the Portneuf River, effectively combining the shallow and deep stream deposits into a single water table aquifer (Bechtel, 1994, p. 2-2). Other aquifers in the East Margin Area include fractured quartzite that has been developed near Blackfoot, stream deposits near the cities of Firth and Basalt.

PWS wells in the East Margin Area of the ESRP province produce water from five different aquifers: the Regional Eastern Snake River Plain aquifer, three alluvial (or stream deposited) aquifers (Eastern Michaud Flats, Firth/Basalt, and Gibson Terrace/Pocatello Bench) and a quartzite aquifer (Blackfoot).

FIGURE 1 - Geographic Location of Nonpareil Processing Corporation, PWS: 6060051



Regional Eastern Snake River Plain Aquifer

The ESRP is a northeast trending basin located in southeastern Idaho. The 10,000 square miles of the plain are primarily filled with highly fractured layered Quaternary-aged basalt flows of the Snake River Group, which are between (intercalated) layers of rocks formed by sediment deposition (sedimentary) along the margins (Garabedian, 1992, p. 5). Quaternary-aged basalts are estimated to be 100 to 1,500 feet thick, with the majority of the area in the range of 100 to 500 feet thick (Whitehead, 1992, Plate 3). Individual basalt flows range from 10 to 50 feet thick, averaging 20 to 25 feet thick (Lindholm, 1996, p. 14). Basalt is thickest in the central part of the eastern plain and thins toward the margins. Whitehead (1992, p. 9) estimates the total thickness of the flows to be as great as 5,000 feet. A thin layer (0 to 100 feet) of windblown and stream-produced sediments overlies the basalt. The plain is bounded on the northeast by rocks of the Yellowstone Group (mainly rhyolite) and Idavada Volcanics to the southwest. These rocks may also underlie the plain (Garabedian, 1992, p. 5). Granite of the Idaho batholith borders the plain to the northwest, along with sedimentary rocks and rocks changed by heat and/or pressure (metamorphic) (Cosgrove et al., 1999, p. 10). The Snake River flows along part of the southern boundary and is the only drainage that leaves the plain. A high degree of connectivity with the regional aquifer system is displayed over much of the river as it passes through the plain. However, some reaches are believed to be perched or separated from the main ground water by unsaturated rock, such as the Lewisville-to-Shelly reach. Rivers and streams entering the plain from the south are tributary to the Snake River. With the exception of the Big and Little Wood rivers, rivers entering from the north vanish into the basalts of the Snake River Plain aquifer that have a higher ability to transmit water.

The layered basalts of the Snake River Group host one of the most productive aquifers in the United States. The aquifer is generally considered unconfined, yet may be confined locally because of interbedded clay and dense unfractured basalt (Whitehead, 1992, p. 26). Whitehead (1992, p. 22) and Lindholm (1996, p.1) report that well yields of 2,000 to 3,000 gallons per minute (gpm) are common for wells open to less than 100 feet of the aquifer. Transmissivities obtained from test data in the upper 100 to 200 feet of the aquifer range from less than 0.1 square feet per second (ft^2/sec) to $56 \text{ ft}^2/\text{sec}$ (1.0×10^4 to $4.8 \times 10^6 \text{ ft}^2/\text{day}$; Garabedian, 1992, p. 11, and Lindholm, 1996, p. 18). Lindholm (1996, p. 18) estimates aquifer thickness to range from 100 feet near the plain's margin to thousands of feet near the center. Models of the regional aquifer have used values ranging from 200 to 3,000 feet to represent aquifer thickness (Cosgrove et al., 1999, p.15).

Regional ground water flow is to the southwest paralleling the basin (Cosgrove et al., 1999; deSonneville, 1972, p. 78; Garabedian, 1992, p. 48; and Lindholm, 1996, p. 23). Reported water table gradients range from 3 to 100 feet/mile and average 12 feet/mile (Lindholm, 1996, p. 22). Gradients steepen at the plain's margin and at discharge locations. The estimated effective ratio of the rock's open space volume to its total volume range from 0.04 to more than 0.25 (Ackerman, 1995, p.1, and Lindholm, 1996, p.16).

The majority of aquifer recharge results from surface water irrigation activities (incidental recharge), which divert water from the Snake River and its tributaries (Ackerman, 1995, p. 4, and Garabedian, 1992, p. 11) and locally from canal leakage. Natural recharge occurs through stream losses, direct precipitation, and tributary basin underflow.

Aquifer discharge occurs primarily as seeps and springs on the northern wall of the Snake River canyon near Thousand Springs and near American Falls and Blackfoot (Garabedian, 1992, p.17). To a lesser degree, discharge also occurs through pumping and underflow.

The East Margin Area is among the most transmissive regions of the regional aquifer, therefore it has a higher ability to transmit water. A transmissivity of $21 \text{ ft}^2/\text{sec}$ was used to represent the upper 200 feet of the regional aquifer in the East Margin Area in the three-dimensional U.S. Geological Survey (USGS) ground water flow model (Garabedian, 1992, Plate 6). The equivalent hydraulic conductivity or the rate at which water can move through permeable material is 9,072 feet per day (ft/day). This value is consistent with the range of hydraulic conductivity (9,500 to 11,708 ft/day) calculated using data from a constant-rate aquifer test conducted in 1981 (Jacobson, 1982, p. 23). This range was calculated by dividing the estimated transmissivity (228,000 to 281,000 ft^2/day) by the perforated interval of the observation well (24 feet). The geometric mean hydraulic conductivity based on analysis of specific capacity data from PWS wells (135 ft/day) is significantly lower.

A published water table map of the Upper Snake River Basin (IDWR, 1997, p. 9) indicates that the ground water flow direction in the ESRP aquifer in the East Margin Area is similar to that depicted at the regional scale (e.g., Garabedian, 1992, Plate 4).

Recharge from precipitation and surface water irrigation in the East Margin Area ranges from less than 10 to more than 20 inches per year (Garabedian, 1992, Plate 8). The low end of the range applies to the area near Blackfoot, while the high end applies to the area on the west side of American Falls Reservoir near Aberdeen.

Kjelstrom (1995, p. 13) reports an annual river loss of 280,000 acre-feet to the regional basalt aquifer for the 27.5-mile Lewisville-to-Shelley reach of the Snake River and 110,000 acre-feet for the 23.5-mile Shelley-to-Blackfoot reach. Annual river gains of 1,900,000 acre-feet for the 36.6-mile Blackfoot-to-Neeley reach are also estimated (Kjelstrom, 1995, p. 13). A seepage study conducted in the fall of 1980 on the Portneuf River showed a gain of about 560 cubic feet per second (ft^3/sec) (405,691 acre-feet) for the 13-mile Pocatello-to-American Falls Reservoir reach (Jacobson, 1982, p. 16). The average flow in the Blackfoot River near the city of Blackfoot is low at Station #13068500 ($5.2 \text{ ft}^3/\text{sec}$; USGS, 2001) compared to the flow in the Snake River near the city of Blackfoot at Station #13069500 ($2,900 \text{ ft}^3/\text{sec}$; USGS, 2001).

The Nonpareil Processing Corporation well is completed, or assumed to be completed in the regional basalt aquifer. Sources of ground water recharge are from surface water irrigation canals in the area and precipitation. The delineated source water assessment area for the Nonpareil Processing Corporation extends in a northeasterly direction and is elongated in shape. The length of the delineation extends approximately 21 miles and extends into the City of Idaho Falls (Appendix B). The delineation for the well is bound by the Snake River on the east side. The actual data used by WGI in determining the source water assessment delineation areas are available from DEQ upon request.

Identifying Potential Sources of Contamination

A potential source of contamination is defined as any facility or activity that stores, uses, or produces, as a product or by-product, the contaminants regulated under the Safe Drinking Water Act. Furthermore, these sources have a sufficient likelihood of releasing such contaminants into the environment at levels that could pose a concern relative to drinking water sources. The goal of the inventory process is to locate and describe those facilities, land uses, and environmental conditions that are potential sources of ground water contamination. Field surveys conducted by DEQ and reviews of available databases identified potential contaminant sources within the delineation areas. The potential contaminant sources within the delineation capture zones include underground storage tank (UST) sites, leaking underground storage tank (LUST) sites, sand and gravel pits, wastewater land application (WLAP) sites, and dairies. Also found were sites regulated under the Superfund Amendments and Reauthorization Act (SARA), the Resource Conservation Recovery Act (RCRA), and the Toxic Release Inventory (TRI). Other sources identified that may contribute to the overall vulnerability of the water source were businesses within the delineated areas that may be considered potential contaminants sources. Additionally, Highway 20, Highway 26, Interstate 15, and a railroad are transportation corridors that cross the delineations.

It is important to understand that a release may never occur from a potential source of contamination provided best management practices are used at the facility. Many potential sources of contamination are regulated at the federal level, state level, or both to reduce the risk of release. Therefore, when a business, facility, or property is identified as a potential contaminant source, this should not be interpreted to mean that this business, facility, or property is in violation of any local, state, or federal environmental law or regulation. What it does mean is that the potential for contamination exists due to the nature of the business, industry, or operation. There are a number of methods that water systems can use to work cooperatively with potential sources of contamination, such as educational visits and inspections of stored materials. Many owners of such facilities may not even be aware that they are located near a public water supply well.

Contaminant Source Inventory Process

A two-phased contaminant inventory of the study area was conducted during August and September of 2002. The first phase involved identifying and documenting potential contaminant sources within the Nonpareil Processing Corporation source water assessment area through the use of computer databases and Geographic Information System (GIS) maps developed by DEQ. The second, or enhanced, phase of the contaminant inventory involved contacting the operator to validate the sources identified in phase one and to add any additional potential sources in the area. This task was undertaken with the assistance of John Kerr. At the time of the enhanced inventory, no additional potential contaminant sources were found within the delineated source water area. A map with the well location, delineated areas, and potential contaminant sources are provided with this report (Appendix B). Each potential contaminant source has been given a unique site number that references tabular information associated with the public water well (Appendix A).

Section 3. Susceptibility Analysis

The susceptibility of the well to contamination was ranked as high, moderate, or low risk according to the following considerations: hydrologic characteristics, physical integrity of the well, land use characteristics, and potentially significant contaminant sources. The susceptibility rankings are specific to a particular potential contaminant or category of contaminants. Therefore, a high susceptibility rating relative to one potential contaminant does not mean that the water system is at the same risk for all other potential contaminants. The relative rankings that are derived for the well is a qualitative, screening-level step that, in many cases, uses generalized assumptions and best professional judgement. Appendix C contains the susceptibility analysis worksheet. The following summaries describe the rationale for the susceptibility rankings.

Hydrologic Sensitivity

The hydrologic sensitivity of a well is dependent upon four factors. These factors are surface soil composition, the material in the vadose zone (between the land surface and the water table), the depth to first ground water, and the presence of a 50-foot thick fine-grained zone above the water producing zone of the well. Slowly draining soils such as silt and clay typically are more protective of ground water than coarse-grained soils such as sand and gravel. Similarly, fine-grained sediments in the subsurface, and a water depth of more than 300 feet from the surface, protect the ground water from contamination.

Hydrologic sensitivity was rated high for the well (Table 1). This is based upon moderate to well drained regional soil classes within the delineated area as defined by the National Resource Conservation Service (NRCS). There was insufficient well log information to evaluate the vadose zone composition, the first depth to ground water, and whether there is at least 50 feet of cumulative thickness of low permeability material that could reduce the downward movement of contaminants. If a well log had been available the hydrologic sensitivity scores may have been lower.

Well Construction

Well construction directly affects the ability of the well to protect the aquifer from contaminants. System construction scores are reduced when information shows that potential contaminants will have a more difficult time reaching the intake of the well. Lower scores imply a system that can better protect ground water. If the casing and annular seal both extend into a low permeability unit then the possibility of cross contamination from other aquifer layers is reduced and the system construction score goes down. If the highest production interval is more than 100 feet below the water table, then the system is considered to have better buffering capabilities. When information was adequate, a determination was made as to whether the casing and annular seals extend into low permeability units and whether current public water system construction standards are met.

The Idaho Department of Water Resources (IDWR) *Well Construction Standards Rules (1993)* require all PWS to follow DEQ standards. IDAPA 58.01.08.550 requires that PWS follow the *Recommended Standards for Water Works (1997)* during construction. Under current standards, all PWS wells are required to have a 50-foot buffer around the wellhead, and if the well is designed to yield greater than 50 gallons per minute (gpm), a minimum of a 6-hour pump test is required. These standards are used to rate the system construction for the well by evaluating items such as condition of the wellhead and surface seal, the thickness of the casing, etc. If all criteria are not met, the public water source does not meet the IDWR Well Construction Standards. In our search for well construction information, we were unable to locate a well driller's log. Because the well's construction could not be accurately assessed and not knowing the approximate age of the well, it is considered that the well does not meet the current IDWR Well Construction Standards for a public water system. Therefore, the well received a conservative rating in terms of system construction susceptibility to contamination.

The system construction score rated high for the well (Table 1). According to the 1998 sanitary survey (conducted by Southeastern District Health Department), the well is believed to have either a 14-inch or 16-inch diameter casing. The recommended casing thickness for a public water well with a 14-inch or 16-inch diameter casing is 0.375-inch. A thicker casing may prolong the life of the well. The wellhead and sanitary seal are acceptable, but the well should be vented and screened to prevent a vacuum from forming when the well is turned on and draws down the water table. A vacuum could draw in contamination through joints or leaks in the casing or cause the well to slough.

It is unknown whether the casing and annular seal extend into a low permeable unit, such as clay, or whether the highest water production for the well is 100 feet below the static water level. If the casing and annular seal extend into a fine-grained medium, this may reduce the chances of laterally migrating contamination into the well. The well casing height is adequate and the well is located outside a 100-year floodplain.

Potential Contaminant Source and Land Use

The potential contaminant sources and land use within the delineated zones of water contribution are assessed to determine the well's susceptibility. When agriculture is the predominant land use in the area, this may increase the likelihood of agricultural wastewater infiltrating the ground water system. Agricultural land is counted as a source of leachable contaminants and points are assigned to this rating based on the percentage of agricultural land. The predominant land use within the delineated capture zones of the Nonpareil Processing Corporation is irrigated agricultural land.

In terms of potential contaminant sources and land use susceptibility the ratings are as follows. The well rated high for IOCs (i.e., nitrates), VOCs (i.e. petroleum related products), and SOC (i.e., pesticides) and moderate for microbial contaminants (i.e., fecal coliform) (Table 1). Most of the potential contaminant sources fall within the 6-year and 10-year TOT zones.

Final Susceptibility Rating

A detection of an IOC above a drinking water standard MCL, or any detection of a VOC or SOC at the wellhead, will automatically give a high susceptibility rating to a well despite the land use of the area, because a pathway for contamination already exists. In this case, the well automatically scored high susceptibility due to the detection of a VOC in the finished drinking water. Additionally, potential contaminant sources within 50 feet of a wellhead will automatically lead to a high susceptibility rating. Hydrologic sensitivity and system construction scores are heavily weighted in the final scores. Having multiple potential contaminant sources in the 0 to 3-year time of travel zone (Zone 1B) and a large percentage of agricultural land contribute greatly to the overall ranking.

Table 1. Summary of Nonpareil Processing Corporation Susceptibility Evaluation

Drinking Water Source	Susceptibility Scores ¹									
	Hydrologic Sensitivity	Potential Contaminant Inventory and Land Use				System Construction	Final Susceptibility Ranking			
		IOC	VOC	SOC	Microbials		IOC	VOC	SOC	Microbials
Well	H	H	H	H	M	H	H	H*	H	H

¹H = High Susceptibility, M = Moderate Susceptibility, L = Low Susceptibility

IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

H* = Indicates source automatically scored as high susceptibility due to the detection of VOCs in the finished drinking water.

Susceptibility Summary

The final susceptibility ranking for the well automatically rated high for VOCs. The well also rated high for IOCs, SOCs, and microbials. These ratings reflect the hydrologic sensitivity, system construction, and potential contaminants inventory and land use within the delineated source water assessment areas for the well.

Total coliform bacteria have not been detected in the distribution system. The IOCs fluoride and nitrate have been detected in the drinking water, but at levels below the MCL for each chemical. The VOC, PCE was detected in March 1999 and June 1999 with concentrations ranging from 0.00072 mg/L to 0.00087 mg/L. The MCL for PCE is 0.005 mg/L. In September 1993, the VOC, trichloroethane was detected in the well water at a concentration of 0.0034 mg/L. The MCL for trichloroethane is 0.005 mg/L. No SOCs have been detected in the drinking water.

The county level agriculture-chemical use is considered high in this area due to the significant amount of agricultural land. Although there may only be a small portion of agriculture land in the direct vicinity of the well, it is useful as a tool in determining the overall chemical usage such as pesticides and how it may impact ground water through infiltration and surface water runoff. In addition, potential sources of contamination were found within the well's delineated TOT zones (Appendix A and Appendix B).

Section 4. Options for Drinking Water Protection

This assessment should be used as a basis for determining appropriate new protection measures or re-evaluating existing protection efforts. No matter what ranking a source receives, protection is always important. Whether the source is currently located in a “pristine” area or an area with numerous industrial and/or agricultural land uses that require surveillance, the way to ensure good water quality in the future is to act now to protect valuable water supply resources. If the system should need to expand in the future, new well sites should be located in areas with as few potential sources of contamination as possible, and the site should be reserved and protected for this specific use.

An effective drinking water protection program is tailored to the particular local drinking water protection area. A community with a fully developed drinking water protection program will incorporate many strategies. For the Nonpareil Processing Corporation, drinking water protection activities should focus on identifying the sources of VOCs in the drinking water. The system should also continue its efforts aimed at keeping the distribution system free of microbial contaminants that may affect the drinking water quality. If PCE or other chemicals tested (i.e. trichloroethane) approach or exceed the MCL, the system should take appropriate measures to treat the water source. Treatments, such as granular activated charcoal and packed tower aeration for VOCs should be investigated to remedy these problems. In addition, drinking water protection activities should focus on correcting any deficiencies outlined in the sanitary survey. Installing a well vent would be a good first step to system improvement. The well should maintain sanitary standards regarding wellhead protection. Also, any new sources that could be considered potential contaminant sources in the well's zones of contribution should also be investigated and monitored to prevent future contamination. No potential contaminants (pesticides, paint, fuel, cleaning supplies, etc.) should be stored or applied within 50 feet of the well. Land uses within most of the source water assessment area are outside the property boundary for the Nonpareil Processing Corporation. Therefore partnerships with federal, state and local agencies, industrial and commercial groups should be established to ensure future land uses are protective of ground water quality. Educating the public and employees about source water will further assist the system in its monitoring and protection efforts.

Due to the time involved with the movement of ground water, drinking water protection activities should be aimed at long-term management strategies even though these strategies may not yield results in the near term. A strong public and employee education program should be a primary focus of any drinking water protection plan. Education topics could include hazardous waste disposal methods and the importance of water conservation to name but a few. There are multiple resources available to help water systems implement protection programs, including the Drinking Water Academy of the EPA. Drinking water protection activities for agriculture should be coordinated with the Idaho State Department of Agriculture and the Bingham County Soil and Water Conservation District. As a major transportation corridor intersects the delineation (Interstate 15, Highway 20, and Highway 26), the Idaho Department of Transportation should be involved in protection efforts.

A system must incorporate a variety of strategies in order to develop a comprehensive drinking water protection plan, be they regulatory in nature (e.g. zoning, permitting) or non-regulatory in nature (e.g. good housekeeping, public education, specific best management practices). For assistance in developing protection strategies please contact the Pocatello Regional Office of the DEQ or the Idaho Rural Water Association.

Assistance

Public water supplies and others may call the following DEQ offices with questions about this assessment and to request assistance with developing and implementing a local protection plan. In addition, draft protection plans may be submitted to the DEQ office for preliminary review and comments.

DEQ Pocatello Regional Office (208) 236-6160

DEQ State Office (208) 373-0502

Website: <http://www.deq.state.id.us>

Water suppliers serving fewer than 10,000 persons may contact Ms. Melinda Harper (208) 343-7001 or email her at mlharper@idahoruralwater.com Idaho Rural Water Association, for assistance with drinking water protection (formerly wellhead protection) strategies.

References Cited

- Ackerman, D.J., 1995, Analysis of Steady-State Flow and Advective Transport in the Eastern Snake River Plain Aquifer System, Idaho, U.S. Geological Survey Water-Resources Investigations, Report 94-4257, 25 p. I-FY95.
- Bechtel Environmental, Inc., 1994, Remedial Investigation/Feasibility Study, Ground water Flow Monitoring Report, 95 p.
- Corbett, M.K., J.E. Anderson, and J.C. Mitchell, 1980, An Evaluation of Thermal Water Occurrences in the Tyhee Area, Bannock County, Idaho, Idaho Department of Water Resources, Water Information Bulletin, No. 30, 67 p.
- Cosgrove, D.M., G.S. Johnson, S. Laney, and J. Lindgren, 1999, Description of the IDWR/UI Snake River Plain Aquifer Model (SRPAM), Idaho Water Resources Research Institute, University of Idaho, 95 p.
- deSonneville, J.L.J., 1972, Development of a Mathematical Ground water Model: Idaho Water Resources Research Institute, University of Idaho, Moscow, Idaho, 227 p.
- Garabedian, S.P., 1992, Hydrology and Digital Simulation of the Regional Aquifer System, Eastern Snake River Plain, Idaho, U.S. Geological Survey Professional Paper 1408-F, 102 p., 10 pl. I-FY92.
- Great Lakes-Upper Mississippi River Board of State and Provincial Public Health and Environment Managers, 1997. "Recommended Standards for Water Works."
- Idaho Division of Environmental Quality Ground Water Program, October 1999. Idaho Source Water Assessment Plan.
- Idaho Department of Environmental Quality. 2000. Design Standards for Public Drinking Water Systems. IDAPA 58.01.08.550.01.
- Idaho Department of Water Resources, 1993. Administrative Rules of the Idaho Water Resource Board: Well Construction Standards Rules. IDAPA 37.03.09.
- Idaho Department of Water Resources, 1997, Upper Snake River Basin Study, 85 p.
- Jacobson, N.D., 1982, Ground-Water Conditions in the Eastern Part of Michaud Flats, Fort Hall Indian Reservation, Idaho, U.S. Geological Survey Open-File Report 82-570, 35 p.
- Jacobson, N.D., 1984, Hydrogeology of Eastern Michaud Flats, Fort Hall Indian Reservation, Idaho, U.S. Geological Survey Water-Resources Investigations Report 84-4201, 42 p.
- Kjelstrom, L.C., 1995, Streamflow Gains and Losses in the Snake River and Ground-Water Budgets for the Snake River Plain, Idaho and Eastern Oregon, U.S. Geological Survey Professional Paper 1408-C, 47 p. I-FY95.
- Lindholm, G.F., 1996, Summary of the Snake River Plain Regional Aquifer-System analysis in Idaho and Eastern Oregon, U.S. Geological Survey Professional Paper 1408-A, 59 p.

- Safe Drinking Water Information System (SDWIS). Idaho Department of Environmental Quality.
- Southeastern District Health Department. 1998. Nonpareil Processing Corporation, Sanitary Survey: PWS #6060051.
- United States Geological Survey, 2001, Current Streamflow Conditions, http://idaho.usgs.gov/rt-cgi/gen_tbl_pg.
- USGS - see United States Geological Survey.
- Washington Group International, Inc, October 2001. Source Area Delineation Report for the East Margin Area of the Eastern Snake River Plain Hydrologic Province.
- Whitehead, R.L., 1992, Geohydrologic Framework of the Snake River Plain Regional Aquifer System, Idaho and Eastern Oregon, U.S. Geological Survey Professional Paper 1408-B, 32p. I-FY92.

POTENTIAL CONTAMINANT INVENTORY LIST OF ACRONYMS AND DEFINITIONS

AST (Aboveground Storage Tanks) – Sites with aboveground storage tanks.

Business Mailing List – This list contains potential contaminant sites identified through a yellow pages database search of standard industry codes (SIC).

CERCLA – This includes sites considered for listing under the **Comprehensive Environmental Response Compensation and Liability Act (CERCLA)**. CERCLA, more commonly known as Superfund is designed to clean up hazardous waste sites that are on the national priority list (NPL).

Cyanide Site – DEQ permitted and known historical sites/facilities using cyanide.

Dairy – Sites included in the primary contaminant source inventory represent those facilities regulated by Idaho State Department of Agriculture (ISDA) and may range from a few head to several thousand head of milking cows.

Deep Injection Well – Injection wells regulated under the Idaho Department of Water Resources generally for the disposal of stormwater runoff or agricultural field drainage.

Enhanced Inventory – Enhanced inventory locations are potential contaminant source sites added by the water system. These can include new sites not captured during the primary contaminant inventory, or corrected locations for sites not properly located during the primary contaminant inventory. Enhanced inventory sites can also include miscellaneous sites added by the Idaho Department of Environmental Quality (DEQ) during the primary contaminant inventory.

Floodplain – This is a coverage of the 100-year floodplains.

Group 1 Sites – These are sites that show elevated levels of contaminants and are not within the priority one areas.

Inorganic Priority Area – Priority one areas where greater than 25% of the wells/springs show constituents higher than primary standards or other health standards.

Landfill – Areas of open and closed municipal and non-municipal landfills.

LUST (Leaking Underground Storage Tank) – Potential contaminant source sites associated with leaking underground storage tanks as regulated under RCRA.

Mines and Quarries – Mines and quarries permitted through the Idaho Department of Lands.)

Nitrate Priority Area – Area where greater than 25% of wells/springs show nitrate values above 5 mg/l.

NPDES (National Pollutant Discharge Elimination System) – Sites with NPDES permits. The Clean Water Act requires that any discharge of a pollutant to waters of the United States from a point source must be authorized by an NPDES permit.

Organic Priority Areas – These are any areas where greater than 25% of wells/springs show levels greater than 1% of the primary standard or other health standards.

Recharge Point – This includes active, proposed, and possible recharge sites on the Snake River Plain.

RCRA – Site regulated under **Resource Conservation Recovery Act (RCRA)**. RCRA is commonly associated with the cradle to grave management approach for generation, storage, and disposal of hazardous wastes.

SARA Tier II (Superfund Amendments and Reauthorization Act Tier II Facilities) – These sites store certain types and amounts of hazardous materials and must be identified under the Community Right to Know Act.

Toxic Release Inventory (TRI) – The toxic release inventory list was developed as part of the Emergency Planning and Community Right to Know (Community Right to Know) Act passed in 1986. The Community Right to Know Act requires the reporting of any release of a chemical found on the TRI list.

UST (Underground Storage Tank) – Potential contaminant source sites associated with underground storage tanks regulated as regulated under RCRA.

Wastewater Land Applications Sites – These are areas where the land application of municipal or industrial wastewater is permitted by DEQ.

Wellheads – These are drinking water well locations regulated under the Safe Drinking Water Act. They are not treated as potential contaminant sources.

NOTE: Many of the potential contaminant sources were located using a geocoding program where mailing addresses are used to locate a facility. Field verification of potential contaminant sources is an important element of an enhanced inventor

APPENDIX A

Nonpareil Processing Corporation Potential Contaminant Source Inventory

Table 2. Potential Contaminants

Site #	Source Description ¹	TOT Zone ² (in years)	Source of Information	Potential Contaminants ³
	Railroad	0-3	GIS MAP	IOC, VOC, SOC, Microbials
	Highway 26	0-3	GIS MAP	IOC, VOC, SOC, Microbials
	Surface Waters	0-3	GIS MAP	IOC, VOC, SOC, Microbials
	Interstate 15	0-3	GIS MAP	IOC, VOC, SOC, Microbials
2	UST Site-Farm; Closed	0-3	Database Search	VOC, SOC
3	UST Site-Utilities; Closed	0-3	Database Search	VOC, SOC
4	Dairy	0-3	Database Search	IOC, Microbials
5	Dairy	0-3	Database Search	IOC, Microbials
6	Dairy	0-3	Database Search	IOC, Microbials
7	Machine Shops	0-3	Database Search	IOC, VOC, SOC
8	Tile-Ceramic-Contractors & Dealers	0-3	Database Search	VOC, SOC
9	Dried/Dehydrated Fruits Veg (Mfr)	0-3	Database Search	IOC, Microbials
10	Truck-Repairing & Service	0-3	Database Search	IOC, VOC, SOC
11	Concrete Contractors	0-3	Database Search	IOC, VOC, SOC
12	RCRA Site	0-3	Database Search	IOC, VOC, SOC
13	RCRA Site	0-3	Database Search	IOC, VOC, SOC
14	Mine/Quarry	0-3	Database Search	IOC, VOC, SOC
15	Mine/Quarry	0-3	Database Search	IOC, VOC, SOC
16	SARA Site	0-3	Database Search	IOC, VOC, SOC
17	Recharge Point	0-3	Database Search	IOC, VOC, SOC, Microbials
18	Recharge Point	0-3	Database Search	IOC, VOC, SOC, Microbials
19	Recharge Point	0-3	Database Search	IOC, VOC, SOC, Microbials
20	Wastewater Land Application Site	0-3	Database Search	IOC, Microbials
21	UST Site-Farm; Closed	3-6	Database Search	VOC, SOC
22	Dairy	3-6	Database Search	IOC
23	Dairy	3-6	Database Search	IOC
24	Delivery Service	3-6	Database Search	VOC, SOC
25	Automobile Body-Repairing & Painting	3-6	Database Search	IOC, VOC, SOC
26	Limousine Service	3-6	Database Search	VOC, SOC
27	Mine/Quarry	3-6	Database Search	IOC, VOC, SOC
28	Recharge Point	3-6	Database Search	IOC, VOC, SOC
29	Recharge Point	3-6	Database Search	IOC, VOC, SOC
30	Recharge Point	3-6	Database Search	IOC, VOC, SOC
31	Recharge Point	3-6	Database Search	IOC, VOC, SOC
32	Recharge Point	3-6	Database Search	IOC, VOC, SOC
33	Wastewater Land Application Site	3-6	Database Search	IOC
34	LUST Site-Cleanup Completed; Impact	6-10	Database Search	VOC, SOC
35	LUST Site-Cleanup Completed; Impact	6-10	Database Search	VOC, SOC
36	LUST Site-Cleanup Completed; Impact	6-10	Database Search	VOC, SOC
37	UST Site-Commercial; Closed	6-10	Database Search	VOC, SOC
38	UST Site-Gas Station; Open	6-10	Database Search	VOC, SOC
39	UST Site-Other; Closed	6-10	Database Search	VOC, SOC
40	UST Site-Other; Open	6-10	Database Search	VOC, SOC
41	UST Site-Not Listed; Closed	6-10	Database Search	VOC, SOC

Site #	Source Description¹	TOT Zone² (in years)	Source of Information	Potential Contaminants³
42	UST Site-Gas Station; Closed	6-10	Database Search	VOC, SOC
43	UST Site-Gas Station; Open	6-10	Database Search	VOC, SOC
44	UST Site-Commercial; Closed	6-10	Database Search	VOC, SOC
45	UST Site-Gas Station; Open	6-10	Database Search	VOC, SOC
46	UST Site-Auto Dealership; Closed	6-10	Database Search	VOC, SOC
47	UST Site-Utilities; Closed	6-10	Database Search	VOC, SOC
48	UST Site-Not Listed; Closed	6-10	Database Search	VOC, SOC
49	UST Site-Not Listed; Closed	6-10	Database Search	VOC, SOC
50	UST Site-Other; Closed	6-10	Database Search	VOC, SOC
51	UST Site-Contractor; Open	6-10	Database Search	VOC, SOC
52	UST Site-Gas Station; Open	6-10	Database Search	VOC, SOC
53	UST Site-Not Listed; Closed	6-10	Database Search	VOC, SOC
54	UST Site-Local Government; Closed	6-10	Database Search	VOC, SOC
55	UST Site-Not Listed; Closed	6-10	Database Search	VOC, SOC
56	UST Site-Truck/Transporter; Open	6-10	Database Search	VOC, SOC
57	UST Site-Auto Dealership; Closed	6-10	Database Search	VOC, SOC
58	UST Site-Not Listed; Closed	6-10	Database Search	VOC, SOC
59	UST Site-Gas Station; Open	6-10	Database Search	VOC, SOC
60	UST Site-Other; Closed	6-10	Database Search	VOC, SOC
61	UST Site-Local Government; Open	6-10	Database Search	VOC, SOC
62	UST Site-Gas Station; Closed	6-10	Database Search	VOC, SOC
63	UST Site-Utilities; Closed	6-10	Database Search	VOC, SOC
64	UST Site-Commercial; Closed	6-10	Database Search	VOC, SOC
65	UST Site-State Government; Closed	6-10	Database Search	VOC, SOC
66	UST Site-Auto Dealership; Closed	6-10	Database Search	VOC, SOC
67	UST Site-Auto Dealership; Closed	6-10	Database Search	VOC, SOC
68	UST Site-Gas Station; Open	6-10	Database Search	VOC, SOC
69	UST Site-Not Listed; Open	6-10	Database Search	VOC, SOC
70	UST Site-Not Listed; Closed	6-10	Database Search	VOC, SOC
71	UST Site-Commercial; Closed	6-10	Database Search	VOC, SOC
72	UST Site-Gas Station; Open	6-10	Database Search	VOC, SOC
73	UST Site-Not Listed; Closed	6-10	Database Search	VOC, SOC
74	UST Site-Other; Closed	6-10	Database Search	VOC, SOC
75	UST Site-Other; Closed	6-10	Database Search	VOC, SOC
76	UST Site-Gas Station; Open	6-10	Database Search	VOC, SOC
77	UST Site-Commercial; Closed	6-10	Database Search	VOC, SOC
78	UST Site-Gas Station; Open	6-10	Database Search	VOC, SOC
79	UST Site-Truck/Transporter; Open	6-10	Database Search	VOC, SOC
80	UST Site-Gas Station; Closed	6-10	Database Search	VOC, SOC
81	Dairy	6-10	Database Search	IOC
82	Automobile Dealers-Used Cars	6-10	Database Search	VOC, SOC
83	Automobile Repairing & Service	6-10	Database Search	IOC, VOC, SOC
84	Hydraulic Equipment-Repairing	6-10	Database Search	VOC, SOC
85	Trucking	6-10	Database Search	VOC, SOC
86	Aircraft Servicing & Maintenance	6-10	Database Search	IOC, VOC, SOC

Site #	Source Description ¹	TOT Zone ² (in years)	Source of Information	Potential Contaminants ³
87	Veterinarians	6-10	Database Search	IOC, VOC
88	Concrete Contractors	6-10	Database Search	IOC, VOC, SOC
89	Boat Dealers	6-10	Database Search	VOC, SOC
90	Steel Fabricators	6-10	Database Search	IOC, VOC
91	Oils-Fuel (Wholesale)	6-10	Database Search	VOC, SOC
92	General Contractors	6-10	Database Search	IOC, VOC, SOC
93	Landscape Contractors	6-10	Database Search	IOC, VOC, SOC
94	Automobile Electric Service	6-10	Database Search	IOC, VOC, SOC
95	Automobile Renting & Leasing	6-10	Database Search	VOC, SOC
96	Automobile Dealers-New Cars	6-10	Database Search	VOC, SOC
97	Automobile Dealers-Used Cars	6-10	Database Search	VOC, SOC
98	Industrial Machinery/Equipment	6-10	Database Search	VOC, SOC
99	General Contractors	6-10	Database Search	IOC, VOC, SOC
100	Tree Service	6-10	Database Search	VOC, SOC
101	Garbage Collection	6-10	Database Search	IOC, VOC, SOC
102	Garbage Collection	6-10	Database Search	IOC, VOC, SOC
103	Property Maintenance	6-10	Database Search	IOC, SOC
104	Boxes-Folding-Manufacturers	6-10	Database Search	VOC
105	Grinding Wheels (Manufacturers)	6-10	Database Search	IOC, VOC
106	Service Stations-Gasoline & Oil	6-10	Database Search	VOC, SOC
107	Service Stations-Gasoline & Oil	6-10	Database Search	VOC, SOC
108	Automobile Lubrication Service	6-10	Database Search	IOC, VOC, SOC
109	Automobile Dealers-New Cars	6-10	Database Search	VOC, SOC
110	Automobile Renting & Leasing	6-10	Database Search	VOC, SOC
111	Landscape Contractors	6-10	Database Search	IOC, VOC, SOC
112	Bus Lines	6-10	Database Search	VOC, SOC
113	Trucking-Heavy Hauling	6-10	Database Search	VOC, SOC
114	Textile Bags (Manufacturers)	6-10	Database Search	VOC
115	General Contractors	6-10	Database Search	IOC, VOC, SOC
116	Oils-Fuel (Wholesale)	6-10	Database Search	VOC, SOC
117	General Contractors	6-10	Database Search	IOC, VOC, SOC
118	Controls Systems/Regulators	6-10	Database Search	IOC, VOC, SOC
119	Cleaners	6-10	Database Search	VOC
120	Fertilizers (Wholesale)	6-10	Database Search	IOC
121	Gazebos	6-10	Database Search	IOC, VOC
122	Service Stations-Gasoline & Oil	6-10	Database Search	VOC, SOC
123	Metal Fabricators	6-10	Database Search	IOC, VOC
124	Truck-Dealers-Used	6-10	Database Search	VOC, SOC
125	Automobile Renting & Leasing	6-10	Database Search	VOC, SOC
126	Trucking-Heavy Hauling	6-10	Database Search	VOC, SOC
127	Coatings-Protective (Manufacturers)	6-10	Database Search	VOC
128	Painters	6-10	Database Search	VOC
129	Electric Motors-Dlrs/Repairing (Wholesale)	6-10	Database Search	IOC, VOC
130	Hardware-Retail	6-10	Database Search	IOC, VOC, SOC
131	Agricultural Chemicals (Wholesale)	6-10	Database Search	IOC, SOC

Site #	Source Description ¹	TOT Zone ² (in years)	Source of Information	Potential Contaminants ³
132	Automobile Repairing & Service	6-10	Database Search	IOC, VOC, SOC
133	Aircraft Servicing & Maintenance	6-10	Database Search	IOC, VOC, SOC
134	Movers	6-10	Database Search	VOC, SOC
135	Grain-Dealers (Wholesale)	6-10	Database Search	IOC
136	Service Stations-Gasoline & Oil	6-10	Database Search	VOC, SOC
137	Paving Contractors	6-10	Database Search	VOC, SOC
138	Engines-Diesel (Wholesale)	6-10	Database Search	VOC, SOC
139	Automobile Dealers-Used Cars	6-10	Database Search	VOC, SOC
140	Automobile Renting & Leasing	6-10	Database Search	VOC, SOC
141	Oils-Fuel (Wholesale)	6-10	Database Search	VOC, SOC
142	Service Industry Machinery (Manufacturers)	6-10	Database Search	VOC, SOC
143	Painters	6-10	Database Search	VOC
144	Trucking-Motor Freight	6-10	Database Search	VOC, SOC
145	Automobile Body-Repairing & Painting	6-10	Database Search	IOC, VOC, SOC
146	Boat Dealers	6-10	Database Search	VOC, SOC
147	Automobile Parts & Supplies-Retail	6-10	Database Search	VOC, SOC
148	Automobile Customizing	6-10	Database Search	IOC, VOC, SOC
149	Tools-Electric (Wholesale)	6-10	Database Search	IOC, VOC
150	General Contractors	6-10	Database Search	IOC, VOC, SOC
151	Gas Companies	6-10	Database Search	VOC, SOC
152	Demolition Contractors	6-10	Database Search	IOC, VOC, SOC
153	Automobile Repairing & Service	6-10	Database Search	IOC, VOC, SOC
154	Trucking-Heavy Hauling	6-10	Database Search	VOC, SOC
155	Automobile Parts & Supplies-Retail	6-10	Database Search	VOC, SOC
156	Campgrounds	6-10	Database Search	IOC, VOC, SOC
157	Asphalt & Asphalt Products	6-10	Database Search	IOC, VOC, SOC
158	Truck-Repairing & Service	6-10	Database Search	IOC, VOC, SOC
159	Movers	6-10	Database Search	VOC, SOC
160	House & Building Movers	6-10	Database Search	VOC, SOC
161	Wrecker Service	6-10	Database Search	IOC, VOC, SOC
162	Veterinarians	6-10	Database Search	IOC, VOC
163	Painters	6-10	Database Search	VOC
164	Trailers-Horse (Wholesale)	6-10	Database Search	VOC, SOC
165	Landscape Contractors	6-10	Database Search	IOC, VOC, SOC
166	Automobile Renting & Leasing	6-10	Database Search	VOC, SOC
167	Movers	6-10	Database Search	VOC, SOC
168	X-Ray Laboratories-Industrial	6-10	Database Search	IOC, VOC, SOC
169	General Contractors	6-10	Database Search	IOC, VOC, SOC
170	Photographers-Portrait	6-10	Database Search	VOC
171	General Contractors	6-10	Database Search	IOC, VOC, SOC
172	Building Contractors	6-10	Database Search	IOC, VOC, SOC
173	Automobile Parts & Supplies-Retail	6-10	Database Search	VOC, SOC
174	Carpet & Rug Cleaners	6-10	Database Search	VOC
175	Electric Equipment & Supplies-Wholesale	6-10	Database Search	IOC, VOC
176	Photographers-Portrait	6-10	Database Search	VOC

Site #	Source Description ¹	TOT Zone ² (in years)	Source of Information	Potential Contaminants ³
177	Automobile Renting & Leasing	6-10	Database Search	VOC, SOC
178	Laboratories-Dental	6-10	Database Search	IOC, VOC, SOC
179	Lawn Mowers	6-10	Database Search	VOC, SOC
180	Laboratories-Testing	6-10	Database Search	IOC, VOC, SOC
181	Aircraft Charter Rental & Leasing	6-10	Database Search	VOC, SOC
182	Dairies	6-10	Database Search	IOC
183	Automobile Renting & Leasing	6-10	Database Search	VOC, SOC
184	Movers	6-10	Database Search	VOC, SOC
185	Hardware-Retail	6-10	Database Search	IOC, VOC, SOC
186	Plumbing Drain & Sewer Cleaning	6-10	Database Search	IOC, VOC
187	Truck-Repairing & Service	6-10	Database Search	IOC, VOC, SOC
188	Truck Renting & Leasing	6-10	Database Search	VOC, SOC
189	Excavating Contractors	6-10	Database Search	IOC, VOC, SOC
190	Contractors-Equipment/Supplies/Dealers	6-10	Database Search	IOC, VOC, SOC
191	Screen Printing	6-10	Database Search	VOC
192	Storage-Household & Commercial	6-10	Database Search	IOC, VOC, SOC
193	Veterinarians	6-10	Database Search	IOC, VOC
194	Car Washing & Polishing	6-10	Database Search	IOC, VOC, SOC
195	Storage-Household & Commercial	6-10	Database Search	IOC, VOC, SOC
196	Automobile-Antique & Classic	6-10	Database Search	VOC, SOC
197	Automobile Dealers-Used Cars	6-10	Database Search	VOC, SOC
198	Government-Forestry Services	6-10	Database Search	VOC, SOC
199	Cleaners	6-10	Database Search	VOC
200	Landscape Contractors	6-10	Database Search	IOC, VOC, SOC
201	Delivery Service	6-10	Database Search	VOC, SOC
202	Buses-Charter & Rental	6-10	Database Search	VOC, SOC
203	Tree Service	6-10	Database Search	VOC, SOC
204	Recycling Centers (Wholesale)	6-10	Database Search	IOC, VOC, SOC
205	Automobile Repairing & Service	6-10	Database Search	IOC, VOC, SOC
206	State Government-Transportation	6-10	Database Search	VOC, SOC
207	Pile Driving Equipment (Manufacturers)	6-10	Database Search	VOC, SOC
208	Truck Renting & Leasing	6-10	Database Search	VOC, SOC
209	Federal Government-National Security	6-10	Database Search	VOC, SOC
210	Truck-Repairing & Service	6-10	Database Search	IOC, VOC, SOC
211	Excavating Contractors	6-10	Database Search	IOC, VOC, SOC
212	Machine Shops	6-10	Database Search	IOC, VOC, SOC
213	Disinfectants & Germicides (Wholesale)	6-10	Database Search	IOC, VOC, SOC
214	Recycling Centers (Wholesale)	6-10	Database Search	IOC, VOC, SOC
215	Transmissions-Automobile	6-10	Database Search	IOC, VOC, SOC
216	Trucking-Heavy Hauling	6-10	Database Search	VOC, SOC
217	Service Stations-Gasoline & Oil	6-10	Database Search	VOC, SOC
218	Automobile Dealers-Used Cars	6-10	Database Search	VOC, SOC
219	Welding Equipment & Supplies (Wholesale)	6-10	Database Search	IOC, VOC
220	Storage-Household & Commercial	6-10	Database Search	IOC, VOC, SOC
221	Metalworking Machinery (Manufacturers)	6-10	Database Search	IOC, VOC

Site #	Source Description ¹	TOT Zone ² (in years)	Source of Information	Potential Contaminants ³
222	Snowmobiles	6-10	Database Search	VOC, SOC
223	Tree Service	6-10	Database Search	VOC, SOC
224	Leather Gloves & Mittens (Manufacturers)	6-10	Database Search	VOC
225	Truck Stops	6-10	Database Search	VOC, SOC
226	TRI	6-10	Database Search	VOC, SOC
227	RCRA Site	6-10	Database Search	SOC
228	RCRA Site	6-10	Database Search	IOC, VOC, SOC
229	RCRA Site	6-10	Database Search	IOC, VOC, SOC
230	RCRA Site	6-10	Database Search	IOC, VOC, SOC
231	RCRA Site	6-10	Database Search	VOC, SOC
232	RCRA Site	6-10	Database Search	IOC, VOC, SOC
233	RCRA Site	6-10	Database Search	VOC, SOC
234	RCRA Site	6-10	Database Search	IOC, VOC, SOC
235	RCRA Site	6-10	Database Search	IOC, VOC, SOC
236	RCRA Site	6-10	Database Search	VOC, SOC
237	RCRA Site	6-10	Database Search	IOC, VOC, SOC
238	Mine/Quarry	6-10	Database Search	IOC, VOC, SOC
239	Mine/Quarry	6-10	Database Search	IOC, VOC, SOC
240	Mine/Quarry	6-10	Database Search	IOC, VOC, SOC
241	Mine/Quarry	6-10	Database Search	IOC, VOC, SOC
242	Mine/Quarry	6-10	Database Search	IOC, VOC, SOC
243	Mine/Quarry	6-10	Database Search	IOC, VOC, SOC
244	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
245	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
246	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
247	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
248	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
249	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
250	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
251	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
252	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
253	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
254	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
255	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
256	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
257	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
258	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
259	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
260	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
261	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
262	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
263	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
264	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
265	Deep Injection Well	6-10	Database Search	IOC, VOC, SOC
266	SARA Site	6-10	Database Search	IOC, VOC, SOC

Site #	Source Description ¹	TOT Zone ² (in years)	Source of Information	Potential Contaminants ³
267	SARA Site	6-10	Database Search	IOC, VOC, SOC
268	SARA Site	6-10	Database Search	IOC, VOC, SOC
269	SARA Site	6-10	Database Search	VOC, SOC
270	SARA Site	6-10	Database Search	VOC, SOC
271	SARA Site	6-10	Database Search	VOC, SOC
272	SARA Site	6-10	Database Search	VOC, SOC
273	SARA Site	6-10	Database Search	IOC, VOC, SOC
274	SARA Site	6-10	Database Search	IOC, VOC, SOC
275	SARA Site	6-10	Database Search	VOC, SOC
276	SARA Site	6-10	Database Search	VOC, SOC
277	SARA Site	6-10	Database Search	VOC, SOC
278	SARA Site	6-10	Database Search	IOC, VOC, SOC
279	SARA Site	6-10	Database Search	IOC, VOC, SOC
280	SARA Site	6-10	Database Search	IOC, VOC, SOC
281	SARA Site	6-10	Database Search	VOC, SOC
282	SARA Site	6-10	Database Search	IOC, VOC, SOC
283	SARA Site	6-10	Database Search	IOC
284	SARA Site	6-10	Database Search	IOC, VOC, SOC
285	Recharge Point	6-10	Database Search	IOC, VOC, SOC
286	Recharge Point	6-10	Database Search	IOC, VOC, SOC
287	AST Site	6-10	Database Search	VOC, SOC
288	AST Site	6-10	Database Search	VOC, SOC
289	AST Site	6-10	Database Search	VOC, SOC

Site# 1 left intentionally out of table

¹ SARA = Superfund Amendments and Reauthorization Act, RCRA = Resource Conservation Recovery Act, TRI = Toxic Release Inventory, UST = underground storage tank, LUST = leaking underground storage tank, AST = above ground storage tank

² TOT = time-of-travel (in years) for a potential contaminant to reach the wellhead

³ IOC = inorganic chemical, VOC = volatile organic chemical, SOC = synthetic organic chemical

APPENDIX B

Nonpareil Processing Corporation Delineation and Potential Contaminant Source Location Map

APPENDIX C

Nonpareil Processing Corporation Susceptibility Analysis Worksheet

The final scores for the susceptibility analysis were determined using the following formulas:

- 1) VOC/SOC/IOC Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.2)
- 2) Microbial Final Score = Hydrologic Sensitivity + System Construction + (Potential Contaminant/Land Use x 0.375)

Final Susceptibility Scoring:

0 - 5 Low Susceptibility

6 - 12 Moderate Susceptibility

13 - 15 High Susceptibility

1. System Construction		SCORE			
Drill Date	unknown				
Driller Log Available	NO				
Sanitary Survey (if yes, indicate date of last survey)	YES	1998			
Well meets IDWR construction standards	NO	1			
Wellhead and surface seal maintained	NO	1			
Casing and annular seal extend to low permeability unit	NO	2			
Highest production 100 feet below static water level	NO	1			
Well located outside the 100 year flood plain	YES	0			
Total System Construction Score		5			
2. Hydrologic Sensitivity					
Soils are poorly to moderately drained	NO	2			
Vadose zone composed of gravel, fractured rock or unknown	YES	1			
Depth to first water > 300 feet	NO	1			
Aquitard present with > 50 feet cumulative thickness	NO	2			
Total Hydrologic Score		6			
3. Potential Contaminant / Land Use - ZONE 1A		IOC Score	VOC Score	SOC Score	Microbial Score
Land Use Zone 1A	IRRIGATED CROPLAND	2	2	2	2
Farm chemical use high	YES	2	0	2	
IOC, VOC, SOC, or Microbial sources in Zone 1A	YES	NO	YES	NO	NO
Total Potential Contaminant Source/Land Use Score - Zone 1A		4	2	4	2
Potential Contaminant / Land Use - ZONE 1B					
Contaminant sources present (Number of Sources)	YES	20	19	19	12
(Score = # Sources X 2) 8 Points Maximum		8	8	8	8
Sources of Class II or III leacheable contaminants or 4 Points Maximum	YES	22	19	13	
Zone 1B contains or intercepts a Group 1 Area	YES	4	4	4	
Land use Zone 1B Greater Than 50% Irrigated Agricultural Land		0	0	2	0
		4	4	4	4
Total Potential Contaminant Source / Land Use Score - Zone 1B		16	16	18	12
Potential Contaminant / Land Use - ZONE II					
Contaminant Sources Present	YES	2	2	2	
Sources of Class II or III leacheable contaminants or	YES	1	1	1	
Land Use Zone II Greater Than 50% Irrigated Agricultural Land		2	2	2	
Potential Contaminant Source / Land Use Score - Zone II		5	5	5	0
Potential Contaminant / Land Use - ZONE III					
Contaminant Source Present	YES	1	1	1	
Sources of Class II or III leacheable contaminants or	YES	1	1	1	
Is there irrigated agricultural lands that occupy > 50% of	YES	1	1	1	
Total Potential Contaminant Source / Land Use Score - Zone III		3	3	3	0
Cumulative Potential Contaminant / Land Use Score		28	26	30	14
4. Final Susceptibility Source Score		17	16	17	16
5. Final Well Ranking		High	High	High	High